



Retail Food Establishment Inspection Report

Establishment Information	
Facility Name BUN RUNNER'S	Facility Type Restaurant
Facility ID # HSAT-7QXAG5	Facility Telephone # 715 588-9209
Facility Address 4620 HWY 47 LAC DU FLAMBEAU , WI 54538	
Licensee Name BUN RUNNERS INC	Licensee Address 12541 GROUSE LN LAC DU FLAMBEAU , WI 54538

Inspection Information		
Inspection Type Routine	Inspection Date 09/27/2016	Total Time Spent

Equipment Temperatures	
Description	Temperature (Fahrenheit)
Hobart Reach-In	38
Prep Cooler	36

Food Temperatures	
Description	Temperature (Fahrenheit)
Chili HH	141
Meatballs HH	146
Hotdogs HH	149
Chopped Onions CH	40
Tomatos CH	37

Warewashing Info						
Machine Name	Sanitization Method	Thermo Label	PPM	Sanitizer Name	Sanitizer Type	Temperature
Four Compartment	Low Temperature Sanitizer		200		Bleach	

Certified Manager		
Name GARY A BLACK	Certificate # KBRN-9A6N2W	Certificate Expiration 05/20/2018

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 1

Good Retail Practices - 53 - Physical facilities installed, maintained and clean

This is a core item

OBSERVATION: The floor is peeling and cracked and no longer easily cleanable.

CORRECTIVE ACTION(S): Provide floors, walls, and ceilings that are designed, constructed, and installed so they are smooth and easily cleanable.

CODE CITATION: 6-201.11 Except as specified under § 6-201.14 and except that antislip floor coverings or applications that may be used for safety reasons, floors, floor coverings, walls, wall coverings, and ceilings shall be designed, constructed, and installed so they are SMOOTH and EASILY CLEANABLE.

Comments

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Sanitarian



TAYLOR HAYNES